

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

RECEIVED
FEB 17 1964

1. County Ozaukee Town ☒ Cedarburg
Village ☐ City ☒ Check one and give name
2. Location SW 1/4 OF SE 1/4 OF SEC. 26 T 10 NR 21 E
Name of street and number of premise or Section, Town and Range numbers
3. Owner ☒ or Agent ☐ John Rindfleisch
Name of individual, partnership or firm
4. Mail Address R. R. Cedarburg, Wis.
Complete address required
5. From well to nearest: Building 12 ft; sewer ft; drain ft; septic tank 45 ft;
dry well or filter bed 60 ft; abandoned well ft.
6. Well is intended to supply water for: House

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	40	6	40	133

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	19.45# well cas.	0	109

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay slurry	0	40

11. MISCELLANEOUS DATA:

Yield test: 10 Hrs. at 11 GPM.
Depth from surface to water-level: 39 ft.
Water-level when pumping: 61 ft.
Water sample was sent to the state laboratory at:
Madison on 2/10/64 19
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Stony Clay	0	109
Limestone	109	133

Construction of the well was completed on:

2/10/64 19

The well is terminated 10 inches
☒ above, below ☐ the permanent ground surface.

Was the well disinfected upon completion?

Yes X No

Was the well sealed watertight upon completion?

Yes X No

Signature Robert D. Duerksen
Registered Well Driller

631 South Wash. Ave. Cedarburg, Wis/
Complete Mail Address

Please do not write in space below

Rec'd FEB 11 1964 No. 5286

Ans'd SAFE—BACTERIOLOGICALLY

Interpretation SAFE—BACTERIOLOGICALLY

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs.

48 hrs.

Confirm

B. Coll

Examiner



0 2 6 1 0 9